



### PRODUCT DESCRIPTION

"EC\*U" type glands are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Group I Mining, Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dusts Groups IIA, IIB and IIC. Occasionally referred to as "potting glands", they provide a compound barrier Ex db & IP seal on the cable inner cores, eliminating damage to cables that exhibit "cold flow" characteristics and an additional environmental seal on the outer sheath. The unique features include, Peppers T1000 or T2000 compound that enables a quick and easy installation. An innovative barrier chamber that allows for a full inspection of the compound fill. The gland maintains IP66, IP68 to 100 metres and IP 69. Is deluge proof without the use of an additional seal or deluge boot. It is supplied with an IP O-ring seal as standard on metric entry threads.

### COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31  
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-15, IEC 60079-31 & IEC 60529

### CERTIFICATION:

<b>UKEX</b>	I M2 II 1D 2G Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex ta IIC Da II 3G Ex nR IIC Gc
<b>ATEX</b>	I M2 II 1D 2G Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex ta IIC Da II 3G Ex nR IIC Gc
<b>IECEX</b>	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIC Da
<b>EAC</b>	PB Ex db I Mb / 1Ex db IIC Gb X / PB Ex eb I Mb X / 1Ex eb IIC Gb X / 2Ex nR IIC Gc X Ex ta IIC Da X
<b>CCC - China</b>	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIC Da
<b>CCoE - India</b>	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIC Da
<b>ABS</b>	Specified ABS Rule
<b>LLOYD'S</b>	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIC Da
<b>DNV</b>	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIC Da

### CERTIFICATION No:

<b>UKEX</b>	CML 21UKEX1036X & CML 21UKEX4037X
<b>ATEX</b>	CML 19ATEX1113X & CML 19ATEX4114X
<b>IECEX</b>	IECEX CML 19.0035X
<b>EAC</b>	RU C-GB.AX58.B.051063/24
<b>CCC - China</b>	2022312313000471
<b>CCoE - India</b>	PESO P494321/17 & P494321/20
<b>ABS</b>	20-LD1944057-PDA
<b>LLOYD'S</b>	LR2124442TA
<b>DNV</b>	TAE00004XK

### EXAMPLE PART NUMBERING: EC2-UB/NP/20/M20

<b>EC</b>	Eclipse style barrier gland for use with Peppers T1000 or T2000 compound
<b>2</b>	Peppers T1000 (1) - Peppers T2000 (2)
<b>U</b>	Gland featuring a compound (Barrier) Inner Seal & Silicone Elastomeric Outer Seal for use with unarmoured cable
<b>2</b>	For use with Lead Sheath Cables
<b>B</b>	Brass (B) / Stainless Steel (S)
<b>C</b>	PVC Shroud (C) - PCP Shroud (P) - LSOH Shroud (3)
<b>K-V-H</b>	Locknut & Nylon (K), Fibre (V) or PTFE (H) IP Washer
<b>T</b>	Including Earth Tag
<b>S</b>	Including Serrated Washer
<b>1</b>	Quantity per kit
<b>NP</b>	Nickel Plated
<b>20</b>	Gland shell size
<b>M20</b>	M20 Entry Thread

### OPTIONAL ACCESSORIES:

<b>LOCKNUT (L)</b>	Brass (ACBLN) / Stainless Steel (ACSLN)
<b>EARTH TAG (T)</b>	Brass (ACBET) / Stainless Steel (ACSET)
<b>IP WASHERS</b>	Nylon (N) / Fibre (J) / PTFE (Z)
<b>SERRATED WASHERS</b>	Stainless Steel (S)
<b>SHROUDS</b>	PVC (C) / PCP (P) / LSOH (3)

<b>IP RATING:</b>	IP66 & IP68 (100 metres - 7 days) & IP69
<b>OPERATING TEMP:</b>	T1000: -60°C to +135°C T2000: -60°C to +120°C
<b>MATERIALS:</b>	Brass or Stainless Steel
<b>PLATING:</b>	Electroless Nickel
<b>COMPOUND:</b>	Peppers T-1000 Compound / Peppers T-2000 Compound
<b>OUTERSEAL:</b>	Silicone LSOH

### CABLE GLAND SELECTION TABLE (ALL DIMENSIONS IN mm)

Gland size	Entry Thread Size		Metric Thread Length [B]	Gland Sealing Range - Cable Sheath & Cores						Nominal Protrusion Length [L]	Dimensions/Weight (Metric)			Shroud Size* (Metric)
	Metric	NPT		Cable Inner Sheath [C]			Cable Outer Sheath [D]		Across Flats [A]		Across Corners	Weight (Kgs)		
				Max Number of Cores [C] [T1000]	Max Number of Cores [C] [T2000]	Max Ø Over Cores [C]	Min Inner Sheath [T2000]	Min					Max	
16S	M16 x 1.5	3/8"	16	12	12	8.9	4.0	3.4	8.4	71	25.4	28.0	0.159	L24
16	M20 x 1.5	1/2"	16	15	15	10.4	4.0	3.4	8.4	71	25.4	28.0	0.174	L24**
20S	M20 x 1.5	1/2" or 3/4"	16	35	15	10.4	4.0	4.8	11.7	72	25.4	28.0	0.175	L24**
20	M20 x 1.5	1/2" or 3/4"	16	40	20	12.5	4.0	9.5	14.0	71	30.0	33.0	0.223	L30
25	M25 x 1.5	3/4" or 1"	16	60	30	16.5	8.0	11.7	18.5	76	37.6	41.4	0.347	L38
32	M32 x 1.5	1" or 1 1/4"	16	80	50	23.5	14.0	18.1	26.3	80	46.0	50.6	0.523	L46
40	M40 x 1.5	1 1/4" or 1 1/2"	16	130	65	28.8	16.0	22.6	32.2	80	55.0	60.5	0.725	L55
50S	M50 x 1.5	1 1/2" or 2"	16	200	100	34.2	20.0	28.2	38.2	93	65.0	71.5	1.108	L65
50	M50 x 1.5	2"	16	400	100	39.4	20.0	33.1	44.1	91	65.0	71.5	1.046	L65
63S	M63 x 1.5	2" or 2 1/2"	19	400	130	44.8	30.0	39.3	50.1	92	80.0	88.0	1.467	L86
63	M63 x 1.5	2 1/2"	19	425	130	50.0	30.0	46.7	56.0	89	80.0	88.0	1.398	L86
75S**	M75 x 1.5	2 1/2" or 3"	19	425	-	55.4	-	52.3	62.0	95	90.0	99.0	1.783	L99
75**	M75 x 1.5	3"	19	425	-	60.8	-	58.0	68.0	92	90.0	99.0	1.687	L99
80**	M80 x 2.0	3" or 3 1/2"	25	425	-	64.4	-	61.9	72.0	113	104.7	115.2	2.969	L104
85**	M85 x 2.0	3" or 3 1/2"	25	425	-	69.8	-	69.1	78.0	110	104.7	115.2	2.526	L104
90**	M90 x 2.0	3 1/2" or 4"	25	425	-	75.1	-	74.1	84.0	107	114.3	125.7	3.008	L114
100**	M100 x 2.0	3 1/2" or 4"	25	425	-	80.5	-	81.8	90.0	109	114.3	125.7	2.544	L114

### NOTES

- Gland size does not necessarily equate to the entry thread size.
- The IP O-ring seal is only available on metric entry threads. IP washers can be supplied for tapered entry threads
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. We usually incorporate a thread run out according to general machining techniques and parts will not have a full form thread for the entire length. Peppers Cable Glands Limited will not be held responsible

- for clients' installations where this has not been taken into account.
- When selecting IP Washer & Shroud material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- The gland is supplied with the correct amount of compound, gloves and instructions to allow one complete termination.
- Where approval in addition to UKEX, ATEX and IECEx is required, this must be clearly requested at time of enquiry / order.
- Size 75S and above only available with T1000 Compound.
- \*\* For gland sizes 16 and 20S when used with 3/4" NPT entry thread an L30 shroud would be required.