

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140326-E248936  
**Report Reference** E248936-20060420  
**Issue Date** 2014-MARCH-26

**Issued to:** PEPPERS CABLE GLANDS LTD  
STANHOPE RD  
CAMBERLEY  
SURREY  
GU15 3BT UNITED KINGDOM

**This is to certify that  
representative samples of**

MARINE SHIPBOARD CABLE SEALING FITTINGS FOR  
USE IN HAZARDOUS LOCATIONS  
See addendum for models.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 2225, Cables and Cable-Fittings for Use in Hazardous  
(Classified) Locations.  
UL 514B, Conduit, Tubing, and Cable Fittings.  
UL 50, Enclosures for Electrical Equipment.


**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140326-E248936  
**Report Reference** E248936-20060420  
**Issue Date** 2014-MARCH-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Cable sealing fittings, for use only with manufacturer's Designation "Peppers T1000 compound" sealing compound: Cat. Nos. UL-U and UL-X followed by B or S, followed by 16, 20S, 20, 25, 32, 40, 50S, 50, 63S, 63, 75S, or 75; followed by M20, M25, M32, M40, M50, M63, M75, 1/2 NPT, 3/4 NPT, 1 NPT, 1-1/4 NPT, 1-1/2 NPT, 2 NPT, 2-1/2 NPT, or 3 NPT, may be followed by -xx; conduit sizes 1/2 in. through 3 in. and M16 through M75 for vertical or horizontal mounting. For use in Class I, Division 2, Groups A, B, C, and D Hazardous Location



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

