




Ex eb : Ex ta : IP66 : Class I Zone 1 : AEx eb : AEx ta



PRODUCT DESCRIPTION

"C*U" type single compression glands are certified Increased Safety Ex eb and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIIA, IIIB and IIIC. Also certified for Zone and Division installations for use with Marine Shipboard and Tray Cables under the NEC and CEC. The gland is suitable for cables that exhibit "cold flow" characteristics, whilst providing an IP66 environmental seal on the cable outer sheath and Peppers multi-armour clamping system for wire, braid and tape armoured cables. The "IE" version allows the gland to be used with HV cables where the fault load is greater than 10.4kA and options are available for use with LSOH cables and extreme temperature applications.

COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-7, EN 60079-31
IEC 60079-0, IEC 60079-7, IEC 60079-31 & IEC 60529
C22.2 (see certificate), CAN/CSA 60079-0/7/31
UL514B, UL1203, UL2225, UL50E, ANSI/UL 60079-0/7, ISA 60079-31

EXAMPLE PART NUMBERING:
C1UBENP/20/05ONPT

C	Gland featuring Peppers Multi-armour clamping system
1	Neoprene Seal (1) - Silicone Seal (3)
U	SWA / SWB or STA
B	Brass (B) / Stainless Steel (S)
IE	Integral Earth (see page 43)
E	Ex e & Ex ta Certification
R	Reduced Bore Seal
C	PVC Shroud (C) - PCP Shroud (P) - LSOH Silicone Shroud (3)
K-V-H	Locknut, Earth Tag & Nylon (K), Fibre (V) or PTFE (H) IP Washer
S	Including Serrated Washer
1	Quantity per kit
NP	Nickel Plated
20	Gland shell size
05ONPT	1/2"NPT Male Entry Thread

OPTIONAL ACCESSORIES:

LOCKNUT	Brass (ACBLN) / Stainless Steel (ACSLN)
EARTH TAG	Brass (ACBET) / Stainless Steel (ACSET)
IP WASHERS	Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)
SERRATED WASHERS	Stainless Steel (ACSSW)
SHROUDS	PVC (ACSPVC) / PCP (ACSPCP) / LSOH Silicone (ACSSIO)

IP RATING:	IP66, Type 4X
OPERATING TEMP:	Neoprene Seals -35°C to +90°C Silicone Seals -60°C to +180°C
MATERIALS:	Brass or Stainless Steel
PLATING:	Electroless Nickel

CERTIFICATION:

UKEX	II 1D 2G Ex eb IIC Gb / Ex ta IIIC Da
ATEX	II 1D 2G Ex eb IIC Gb / Ex ta IIIC Da
IECEx	Ex eb IIC Gb / Ex ta IIIC Da
CEC - Canada	Ex eb IIC Gb / Ex ta IIIC Da Class II Group E, F & G Class III Type 4X
NEC - USA	Class I Zone 1 AEx eb IIC Gb / Zone 20 AEx ta IIIC Da Class II Group E, F & G Class III Type 4X
INMETRO - Brazil	Ex eb IIC Gb / Ex ta IIIC Da
CCC - China	Ex e IIC Gb / Ex tD A20
CCoE - India	Ex eb IIC Gb / Ex ta IIIC Da
ABS	Specified ABS Rules
LLOYD'S	Ex eb IIC Gb / Ex ta IIIC Da

CERTIFICATION No:

UKEX	CML 21UKEX1035X
ATEX	CML 19ATEX1106X
IECEx	IECEx CML 19.0031X
CEC - Canada	CSA 1356011
NEC - USA	CSA 1356011
INMETRO - Brazil	NCC 13.2186 X
CCC - China	2021312313000406
CCoE - India	PESO P494321/4
ABS	20-LD1944057-PDA
LLOYD'S	LR2124442TA

CABLE GLAND SELECTION TABLE
(ALL DIMENSIONS IN mm)

Gland size	Entry Thread Size		Metric Thread Length [B]	Cable Acceptance Details					Armour Acceptance Range		Nominal Protrusion Length [L]	Dimensions/Weight (Metric)			Shroud Size* (Metric)	
	Metric	NPT		Inner Sheath [C]		Outer Sheath [D]		Reduced [D]		Orientation 1		Orientation 2	Across Flats [A]	Across Corners		Weight Kgs
				Min	Max	Min	Max	Min	Max							
16	M16 x 1.5	3/8" or 1/2"	16	N/A	8.4	8.4	13.5	4.9	10.0	0.80-1.25	0.20-0.80	58	24.0	26.5	0.143	L24*
16	M20 x 1.5	1/2" or 3/4"	16	N/A	8.4	8.4	13.5	4.9	10.0	0.80-1.25	0.20-0.80	58	24.0	26.5	0.154	L24*
20S	M20 x 1.5	1/2" or 3/4"	16	N/A	11.7	11.5	16.0	9.4	12.5	0.80-1.25	0.20-0.80	58	24.0	26.5	0.125	L24*
20	M20 x 1.5	1/2" or 3/4"	16	N/A	14.0	15.5	21.1	12.0	17.6	0.80-1.25	0.20-0.80	58	30.0	33.0	0.180	L30
25	M25 x 1.5	3/4" or 1"	16	N/A	20.0	20.3	27.4	16.8	23.9	1.25-1.60	0.20-0.80	58	37.6	41.4	0.256	L38
32	M32 x 1.5	1" or 1 1/4"	16	N/A	26.3	26.7	34.0	23.2	30.5	1.60-2.00	0.30-1.20	65	46.0	50.6	0.400	L46
40	M40 x 1.5	1 1/4" or 1 1/2"	16	N/A	32.2	33.0	40.6	28.6	36.2	1.60-2.00	0.30-1.20	72	55.0	60.5	0.649	L55
50S	M50 x 1.5	1 1/2" or 2"	16	N/A	38.2	39.4	46.7	34.8	42.4	2.00-2.50	0.30-1.60	73	65.0	71.5	0.940	L65
50H	M50 x 1.5	1 1/2" or 2"	16	N/A	38.2	45.7	53.2	41.1	48.5	2.00-2.50	0.30-1.60	73	65.0	71.5	0.849	L65
50	M50 x 1.5	2"	16	N/A	44.1	45.7	53.2	41.1	48.5	2.00-2.50	0.30-1.60	73	65.0	71.5	0.707	L65
63S	M63 x 1.5	2" or 2 1/2"	19	N/A	50.1	52.1	59.5	47.5	54.8	2.00-2.50	0.30-1.60	76	80.0	88.0	1.369	L80
63H	M63 x 1.5	2" or 2 1/2"	19	N/A	50.1	58.4	65.8	53.8	61.2	2.00-2.50	0.30-1.60	76	80.0	88.0	1.306	L80
63	M63 x 1.5	2 1/2"	19	N/A	56.0	58.4	65.8	53.8	61.2	2.00-2.50	0.30-1.60	76	80.0	88.0	1.123	L80
75S	M75 x 1.5	2 1/2" or 3"	19	N/A	62.0	64.8	72.2	60.2	68.0	2.00-2.50	0.50-1.60	82	90.0	99.0	1.661	L90
75H	M75 x 1.5	2 1/2" or 3"	19	N/A	62.0	71.1	78.0	66.5	73.4	2.00-2.50	0.50-1.60	82	90.0	99.0	1.553	L90
75	M75 x 1.5	3"	19	N/A	68.0	71.1	78.0	66.5	73.4	2.00-2.50	0.50-1.60	82	90.0	99.0	1.310	L90
80	M80 x 2.0	3" or 3 1/2"	25	N/A	72.0	77.0	84.0	71.9	79.4	3.15-4.00	0.50-1.60	110	104.0	115.2	2.718	L104
80H	M80 x 2.0	3" or 3 1/2"	25	N/A	72.0	79.6	90.0	75.0	85.4	3.15-4.00	0.50-1.60	110	104.0	115.2	2.489	L104
85	M85 x 2.0	3" or 3 1/2"	25	N/A	78.0	79.6	90.0	75.0	85.4	3.15-4.00	0.50-1.60	110	104.0	115.2	2.326	L104
90	M90 x 2.0	3 1/2" or 4"	25	N/A	84.0	88.0	96.0	82.0	91.4	3.15-4.00	0.50-1.60	110	114.0	125.7	2.852	L114
90H	M90 x 2.0	3 1/2" or 4"	25	N/A	84.0	92.0	102.0	87.4	97.4	3.15-4.00	0.50-1.60	110	114.0	125.7	2.629	L114
100	M100 x 2.0	3 1/2" or 4"	25	N/A	90.0	92.0	102.0	87.4	97.4	3.15-4.00	0.50-1.60	110	114.0	125.7	2.496	L114

NOTES

- Gland size does not necessarily equate to the entry thread size.
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. We usually incorporate a thread run out according to general machining techniques and parts will not have a full form thread for the entire length. Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer & Shroud material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Orientation 2 Min ranges stated are for double layer braid and single layer tape.
- Where approval in addition to UKEX, ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.
- * For gland sizes 16 and 20S when used with 3/4" NPT entry thread an L30 shroud would be required.