
Single Seal Barrier Gland featuring Peppers T2000 or T1000 Compound with Male Thread for Conduit Connection

Ex db : Ex eb : Ex nR : Ex ta : IP66 : IP68 : IP69



Eclipse style barrier gland for use with Peppers T1000 or T2000 compound EC Peppers T1000 (1) - Peppers T2000 (2) Gland featuring a compound (Barrier) Inner Seal for use with conduit Brass (B) / Stainless Steel (S) Back End Configuration: Male (M) K-V-H Locknut & Nylon (K), Fibre (V) or PTFE (H) IP Washer Including Earth Tag Including Serrated Washer Quantity per kit 20 Gland shell size NP Nickel Plated M20 x 1.5 Male Entry Thread 1/2"NPT Male Connection Thread

LOCKNUT (L)	Brass (ACBLN) / Stainless Steel (ACSLN)					
EARTH TAG (T)	Brass (ACBET) / Stainless Steel (ACSET)					
IP WASHERS	Nylon (N) / Fibre (J) / PTFE (Z)					
SERRATED WASHERS	Stainless Steel (S)					

IP RATING:	IP66 & IP68 (100 metres - 7 days) & IP69				
OPERATING TEMP:	T1000: -60°C to +135°C				
	T2000: -60°C to +120°C				
MATERIALS:	Brass or Stainless Steel				
PLATING:	Electroless Nickel				
COMPOUND:	Peppers T-1000 Compound / Peppers T-2000 Compound				

UK CE W W D W ABS R DNV

PRODUCT DESCRIPTION

"EC*-S*M" type glands, used in any orientation, are certified Flameproof Ex db, Increased Safety Ex eb, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Group I Mining, Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dusts Groups IIIA, IIIB and IIIC. Commonly referred to as a "Conduit Stopper Box" they are suitable for use with conductors carried in conduit or as a line bushing for terminating flying leads. They provide a compound barrier Ex db & IP seal on the cable inner cores, eliminating damage to cables that exhibit "cold flow" characteristics. The unique features include, Peppers T1000 or T2000 compound that enables a quick and easy installation. An innovative barrier chamber that allows for a full inspection of the compound fill. The gland maintains IP66, IP68 to 100 metres and IP 69. Is deluge proof without the use of an additional seal or deluge boot. It is supplied with an IP O-ring seal as standard on metric entry threads. The gland is supplied with a male conduit connection thread.

COMPLIANCE STANDARDS:

CERTIFICATION

CERTIFICATION No:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31 JEC 60079-0, JEC 60079-1, JEC 60079-7, JEC 60079-15, JEC 60079-31 & JEC 60529

1.0 000/3-0, IEC 000/3-1, IEC 000/3-7, IEC 000/3-13, IEC 000/3-31 & IEC 00323						
	UKEX	I M2 II 1D 2G Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex ta IIIC Da				
		II 3G Ex nR IIC Gc				
	ATEX	I M2 II 1D 2G Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex ta IIIC Da				
		II 3G Ex nR IIC Gc				
	IECEx	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				
	EAC	PB Ex db I Mb X / 1Ex db IIC Gb X / PB Ex eb I Mb x / 1Ex eb IIC Gb X / 2Ex nR IIC Gc X				
		Ex ta IIIC Da X				
	CCC - China	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				
	CCoE - India	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				
	ECAS-Ex	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				
	ABS	Specified ABS Rule				
	LLOYD'S	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				
	DNV	Ex db I Mb / Ex db IIC Gb / Ex eb I Mb / Ex eb IIC Gb / Ex nR IIC Gc / Ex ta IIIC Da				

UKEX	CML 21UKEX1036X & CML 21UKEX4037X					
ATEX	CML 19ATEX1113X & CML 19ATEX4114X					
IECEx	IECEx CML 19.0035X					
EAC	RU C-GB.AЖ58.B.05106/24					
CCC - China	2022312313000471					
CCoE - India	PESO P494321/17 & P494321/20					
ECAS-Ex	25-06-153223/E25-06-159811/NB0007					
ABS	25-0158110-PDA					
LLOYD'S	LR2124442TA					
DANY	TAF00004VI/					

,		
	ı	

EXAMPLE PART NUMBERING: EC2-SBM20/NP/M20/050NPT

Gland size	Entry Thread Size		Metric Thread	Female Entry Threads										
						Max Number	Max Number	Max Ø Over	Min Inner	Max Outer	Nominal Protrusion	Dimensions/Weight (Metric)		
	Metric	NPT	Length [B]	Metric	NPT	of Cores [C] [T1000]	of Cores [C] [T2000]	Cores [C]	Sheath [T2000]	Sheath [D]	Length [L]	Across Flats [A]	Across Corners	Weight (Kgs)
16S	M16 x 1.5	3/8"	16	M16	3/8"	12	12	8.9	4.0	10.0	56	25.4	28.0	0.139
20	M20 x 1.5	1/2" or 3/4"	16	M20	1/2" or 3/4"	40	20	12.5	4.0	14.0	58	30.0	33.0	0.192
25	M25 x 1.5	3/4" or 1"	16	M25	3/4" or 1"	60	30	16.5	8.0	18.5	63	37.6	41.4	0.291
32	M32 x 1.5	1" or 1 1/4"	16	M32	1" or 1 1/4"	80	50	23.5	14.0	26.3	64	46.0	50.6	0.449
40	M40 x 1.5	1 ¼" or 1 ½"	16	M40	1 1/4" or 1 1/2"	130	65	28.8	16.0	32.2	60	55.0	60.5	0.603
50S	M50 x 1.5	1 ½" or 2"	16	M50	1½" or 2"	200	100	34.2	20.0	38.2	66	65.0	71.5	0.678
50	M50 x 1.5	2"	16	M50	2"	400	100	39.4	20.0	44.1	66	65.0	71.5	0.678
63S	M63 x 1.5	2" or 2 ½"	19	M63	2" or 2 ½"	400	130	44.8	30.0	50.1	70	80.0	88.0	1.062
63	M63 x 1.5	2 ½"	19	M63	2 ½"	425	130	50.0	30.0	56.0	70	80.0	88.0	1.062
75S*	M75 x 1.5	2 ½" or 3"	19	M75	2 ½" or 3"	425	-	55.4	-	62.0	70	90.0	99.0	1.165
75*	M75 x 1.5	3"	19	M75	3"	425	-	60.8	-	68.0	70	90.0	99.0	1.165
80*	M80 x 2.0	3" or 3 ½"	25	M80	3" or 3 ½"	425	-	64.4	-	72.0	87	104.7	115.2	2.492
85*	M85 x 2.0	3" or 3 ½"	25	M85	3" or 3 ½"	425	-	69.8	-	78.0	85	104.7	115.2	2.051
90*	M90 x 2.0	3 ½" or 4"	25	M90	3 ½" or 4"	425	-	75.1	-	84.0	85	114.3	125.7	2.455
100*	M100 x 2.0	3 ½" or 4"	25	M100	3 ½" or 4"	425	-	80.5	-	90.0	85	114.3	125.7	2.223

Gland Sealing Range - Cable Sheath & Cores

- Gland size does not necessarily equate to the entry thread size.
- The IP O-ring seal is only available on metric entry threads. IP washers can be supplied for tapered entry threads
- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
- Peppers supplies cable glands with parallel entry threads that conform to the flameproof
 threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. We usually
 incorporate a thread run out according to general machining techniques and parts will not
 have a full form thread for the entire length. Peppers Cable Glands Limited will not be held
- responsible for clients' installations where this has not been taken into account.
- When selecting IP Washer & Shroud material for use with glands, please be aware of the
 accessories temperature range to ensure they are suitable for the intended installation.
- The gland is supplied with the correct amount of compound, gloves and instructions to allow one complete termination.
- Where approval in addition to UKEX, ATEX and IECEx is required, this must be clearly requested at time of enquiry / order.
- * Size 75S and above only available with T1000 Compound.

40