



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	25-06-153223/E25-06-159811/NB0007	رقم الشهادة:
Registration Date:	13/06/2025	تاريخ التسجيل:
Valid Until:	12/06/2028	صالحة لغاية:
Issued To:	Peppers Cable Glands Limited P.O. Box GU15 3BT , Stanhope Road Camberley , United Kingdom	أصدرت إلى :
Sector:	Electrical	قطاع: كهرباء
Product Category:	ECAS-Ex	تصنيف المنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات

intertek
Total Quality. Assured.
جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

www.moiat.gov.ae

[Instagram](https://www.instagram.com/moiat) [Facebook](https://www.facebook.com/moiat) [YouTube](https://www.youtube.com/moiat) [LinkedIn](https://www.linkedin.com/moiat) @MoIAT



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

Company Name: Peppers Cable Glands Limited **اسم الشركة:**

Product Category: ECAS-Ex **تصنيف المنتج:** الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Certificate No.: 25-06-153223/E25-06-159811/NB0007 **رقم التسجيل:**

Registration Date: 13/06/2025 **تاريخ التسجيل:**

Valid Until: 12/06/2028 **صالح لغاية:**

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
--------	-----------------------------	-----------------------------	----------------------------------	-----------------------------	---------------------------------	---------------------	---	---------------------------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

1	Peppers	CR	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection , Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : $-35^{\circ}\text{C} \leq T_s \leq +90^{\circ}\text{C}$ – Neoprene (black) seals, $-60^{\circ}\text{C} \leq T_s \leq +180^{\circ}\text{C}$ – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0106X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
2	Peppers	CR-D	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : $-35^{\circ}\text{C} \leq T_s \leq +90^{\circ}\text{C}$ – Neoprene (black) seals, $-60^{\circ}\text{C} \leq T_s \leq +180^{\circ}\text{C}$ – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0106X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

3	Peppers	CR-O	Cable Glands; Type of Protection: Increased Safety, Dust Protection; Marking: Ex eb IIC Gb, Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0106X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
4	Peppers	ED*U	Armour Cable Glands; Type of Protection: Flameproof , Increased Safety , Dust Protection, Restricted Breathing Ex nR; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da ; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 21.0157X GB/CML/ExTR21.0282/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

5	Peppers	E****F*	Cable Glands; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ;Marking:Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc ; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 19.0031X GB/CML/ExTR19.0070/00 GB/CML/ExTR19.0200/00 GB/CML/ExTR19.0245/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
6	Peppers	D****F	Cable Glands; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ;Marking:Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc ; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 19.0031X GB/CML/ExTR19.0070/00 GB/CML/ExTR19.0200/00 GB/CML/ExTR19.0245/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

7	Peppers	C****E*	Cable Glands; Type of Protection: Increased Safety , Dust Protection ; Marking: Ex eb IIC Gb, Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 19.0031X GB/CML/ExTR19.0070/00 GB/CML/ExTR19.0200/00 GB/CML/ExTR19.0245/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
8	Peppers	A*L**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp: -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

9	Peppers	A*LDS**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
10	Peppers	A*RDC**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

11	Peppers	A*RDF**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-11, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
12	Peppers	A*RDM**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

13	Peppers	A*LCH**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
14	Peppers	A*LCF**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

15	Peppers	A*LCM**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-16, UAE.S IEC 60079-31	United Kingdom
16	Peppers	A*RC***	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0103X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

17	Peppers	A*E**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
18	Peppers	A*EDS**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

19	Peppers	A*ERDC**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
20	Peppers	A*ERDF**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

21	Peppers	A*ERDM**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
22	Peppers	A*ECH**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

23	Peppers	A*ECF**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
24	Peppers	A*ECM**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-25, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

25	Peppers	A*ERCC**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-26, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
26	Peppers	A*ERCF**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-27, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

27	Peppers	A*ERCM**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Restricted Breathing, Dust Protection; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc. Ex ta IIIC Da; Temp : -35°C ≤ Ts ≤ +90°C – Neoprene (black) seals, -60°C ≤ Ts ≤ +180°C – Silicone (white & red) seals	N/A	NA	IECEX CML 20.0131X GB/CML/ExTR20.0177/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-28, UAE.S IEC 60079-31	United Kingdom
28	Peppers	A8**	Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

29	Peppers	A8C***	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
30	Peppers	A8RC**	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

31	Peppers	E8X*F	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
32	Peppers	E8XC**F	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

33	Peppers	D8X*F	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
34	Peppers	D8XC*F	Cable Glands;Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db IIC Gb, Ex eb IIC Gb , Ex ta IIIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +180°C – Silicone (white) seals	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0104X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

35	Peppers	CR-C	Barrier Cable Glands and Stopper Boxes; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEX CML 19.0046X GB/CML/ExTR19.0133/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
36	Peppers	CR-U	Barrier Cable Glands and Stopper Boxes; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEX CML 19.0046X GB/CML/ExTR19.0133/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

37	Peppers	CR-S	Barrier Cable Glands and Stopper Boxes; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEX CML 19.0046X GB/CML/ExTR19.0133/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
38	Peppers	CR-X	Barrier Cable Glands and Stopper Boxes; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEX CML 19.0046X GB/CML/ExTR19.0133/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

39	Peppers	UL-C	Barrier Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb , Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da, Temp: -60°C to 135°C	N/A	NA	IECEX CML 19.0046X GB/CML/ExTR19.0133/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
40	Peppers	UL-U	Barrier Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb , Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da, Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0107X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

41	Peppers	UL-X	Barrier Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb, Ex eb I Mb , Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da, Temp: -60°C to 135°C	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0107X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
42	Peppers	LT-C	Barrier Cable Glands; Type of Protection: Flameproof, Increased Safety, Dust Protection, Restricted Breathing; Marking: Ex db I Mb , Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc ; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0049X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

43	Peppers	EC* C	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	----------	--	-----	----	--	---	-------------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

44	Peppers	EC*S*C	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	--------	---	-----	----	--	---	----------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

45	Peppers	EC*S*M	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	--------	---	-----	----	--	---	----------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

46	Peppers	EC*S*F	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	--------	---	-----	----	--	---	----------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

47	Peppers	EC*U	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	------	---	-----	----	--	---	----------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

48	Peppers	EC*X	Cable Glands and Stopper Boxes; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIC Da, Ex nR IIC Gc; Temp : -60°C ≤ Ts ≤ +135°C – T1000 Compound, -60°C ≤ Ts ≤ +120°C – T2000 Compound	N/A	NA	IECEX CML 19.0035X GB/CML/ExTR19.0074/00 GB/CML/ExTR21.0160/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	---------	------	---	-----	----	--	---	----------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

49	Peppers	AR	Adaptors and Reducers; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ;Marking: Ex db I Mb / Ex eb I Mb , Ex db IIC Gb / Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; For Temperature details please refer:IECEx CML 19.0022X	N/A	NA	IECEx CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
50	Peppers	ARFF	Adaptors and Reducers; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ;Marking: Ex db I Mb / Ex eb I Mb , Ex db IIC Gb / Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; For Temperature details please refer:IECEx CML 19.0022X	N/A	NA	IECEx CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

51	Peppers	ARMM	Adaptors and Reducers; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ;Marking: Ex db I Mb / Ex eb I Mb , Ex db IIC Gb / Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; For Temperature details please refer:IECEx CML 19.0022X	N/A	NA	IECEx CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
52	Peppers	ARMR	Adaptors and Reducers;Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking:Ex db I Mb,Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da;For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEx CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

53	Peppers	ARFR	Adaptors and Reducers;Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking:Ex db I Mb,Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da;For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEX CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
54	Peppers	AEMF	Adaptors and Reducers;Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking:Ex db I Mb,Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da;For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEX CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

55	Peppers	AEFF	Adaptors and Reducers;Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking:Ex db I Mb,Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da;For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEX CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
56	Peppers	ATMF	Adaptors and Reducers;Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking:Ex db I Mb,Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da;For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEX CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

57	Peppers	ATFF	Adaptors and Reducers; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; For Temperature details please refer IECEx CML 19.0023U	N/A	NA	GB/CML/ExTR19.0061/00 IECEX CML 19.0023U GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
58	Peppers	RAFF	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEX CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



تم إصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

59	Peppers	RAFF 90	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEx CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
60	Peppers	RAMF	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEx CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

61	Peppers	RAMF 90	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEx CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
62	Peppers	RAMM	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEx CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

63	Peppers	RAMM 90	Rotating Adaptors Reducers and Elbows; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb, Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Temp : -60°C ≤ Ts ≤ +135°C	N/A	NA	IECEx CML 19.0101X GB/CML/ExTR19.0164/00 GB/CML/ExTR19.0164/01 GB/CML/ExTR20.0040/00 GB/CML/ExTR21.0287/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
64	Peppers	SPA	Stopping Plugs;Type of Protection: Flameproof , Increased Safety , Dust Protection ; Marking: Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb,Ex ta IIIC Da; For Temperature details please refer: IECEx CML 19.0022X	N/A	NA	IECEx CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

65	Peppers	SPB	Stopping Plugs; Type of Protection: Flameproof , Increased Safety , Dust Protection ; Marking: Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIC Da; For Temperature details please refer: IECEx CML 19.0022X	N/A	NA	IECEX CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	United Kingdom
66	Peppers	SPMH	Stopping Plugs; Type of Protection: Flameproof , Increased Safety, Restricted Breathing , Dust Protection ; Marking: Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC Da; For Temperature details please refer: IECEx CML 19.0022X	N/A	NA	IECEX CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

67	Peppers	SPMH*NE	Non-metallic stopping plugs; Type of Protection: Increased Safety 'eb', Dust Protection; Marking: Ex eb IIC Gb, Ex ta IIIC Da; For temperature details please refer : IECEx CML 17.0145X	N/A	NA	IECEX CML 17.0145X GB/CML/ExTR17.0176/00 GB/CML/ExTR21.0248/00 GB/CML/ExTR18.0303/00 GB/CML/ExTR21.0163/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
68	Peppers	SPHH	Stopping Plugs; Type of Protection: Flameproof , Increased Safety , Restricted Breathing , Dust Protection ; Marking: Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; For Temperature details please refer: IECEx CML 19.0022X	N/A	NA	IECEX CML 19.0022X GB/CML/ExTR19.0061/00 GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

69	Peppers	ACDP	Breather Drains; Type of Protection: Increased Safety, Dust Protection; Marking: Ex eb IIC Gb, Ex eb I Mb, Ex ta IIIC Da; for temperature details please refer IECEx CML 19.0105X	N/A	NA	GB/CML/ExTR19.0133/00 IECEX CML 19.0105X GB/CML/QAR19.0022/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
Nothing Follows								



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology

